

# Merrickville Wastewater System

---

## 2021 Annual Report

January 1, 2021 – December 31, 2021

Prepared By



**Ontario Clean Water Agency**  
**Agence Ontarienne Des Eaux**

This report has been prepared to meet the requirements set out in the facility Certificate of Approval #1121-7YRQLF issued January 18, 2010.

# Contents

<b>Compliance Report Card</b> .....	<b>1</b>
<b>System/Process Description</b> .....	<b>1</b>
Proposed Alterations, Extensions, or Replacement to Works.....	2
<b>Effluent Quality Assurance or Control Measures</b> .....	<b>2</b>
<b>Treatment Flows</b> .....	<b>3</b>
Raw Flow (m <sup>3</sup> /d) .....	3
Annual Comparison (m <sup>3</sup> ) .....	3
Septage Volumes .....	4
<b>Raw Sewage Quality</b> .....	<b>4</b>
<b>Effluent Quality</b> .....	<b>4</b>
Effluent Exceedance Summary Limit .....	4
Other Issues .....	4
Effluent Parameter Summary .....	5
Carbonaceous Biological Oxygen Demand (CBOD <sub>5</sub> ) .....	5
Total Suspended Solids .....	6
Total Phosphorus .....	7
Total Ammonia Nitrogen.....	8
Acute Lethality .....	8
E-coli.....	9
pH.....	9
<b>Biosolids</b> .....	<b>10</b>
Biosolids Disposal Summary .....	10
Annual Comparison .....	10
<b>Summary of Complaints</b> .....	<b>10</b>
<b>Summary of Bypass/Overflows</b> .....	<b>11</b>
<b>Summary of Spills/Abnormal Discharges</b> .....	<b>11</b>
<b>Maintenance</b> .....	<b>11</b>
Maintenance Highlights.....	11
Calibration .....	12
<b>Facility Performance Assessment Report</b> .....	<b>A</b>
<b>Biosolids Quality Report</b> .....	<b>B</b>
<b>Flow Meter Calibration Records</b> .....	<b>C</b>

## Compliance Report Card

Compliance Event	# of Events	Details
Ministry of Environment Inspections	0	No Inspection's during the reporting period
Ministry of Labour Inspections	0	No Inspection's during the reporting period
Effluent Parameter Exceedances	1	Phosphorus exceeded the regulatory limit in February 2021
Bypass/Overflows	0	No Bypass or Overflows to report for this reporting period
Community Complaints	0	No community complaints during the reporting period
Spills	1	1 spill during the reporting period

## System/Process Description

The Merrickville Wastewater system utilizes an ISAM treatment system. This system incorporates a surge/anoxic mix tank as part of the tank to optimally control the process and provides rapid and complete treatment. The surge tank provides flow and nutrient equalization to optimally provide treatment at the full range of flows and loadings.

The secondary treatment process employs sequencing batch reactor (SBR) technology consisting of anaerobic tanks, anoxic tanks and a sequencing batch reactor. The Sequencing Batch Reactor incorporates an anaerobic selector chamber which provides consistent phosphorous removal by subjecting the recirculated biomass to anaerobic conditions, forcing the release of phosphorous, but also creates soluble carbon as a food source for phosphorous removal through anaerobic conversion of settle able BOD to soluble carbon. Additionally, anaerobic sludge digestion occurs in the anaerobic selector chamber, reducing waste solids production by up to 65% for the entire secondary process. Effluent is disinfected using Ultraviolet disinfection. Permanent Diesel generator is on-site to provide back-up power.

### Proposed Alterations, Extensions, or Replacement to Works

There are no proposed alterations, extensions or replacements that would affect the Certificate of Approval.

## Effluent Quality Assurance or Control Measures

The Village of Merrickville-Wolford facilities are part of OCWA's operational Mississippi Cluster. The facilities are supported by cluster, regional and corporate resources. Operational Services are delivered by OCWA staff that live and work in the community.

OCWA operates facilities in compliance with applicable regulations. The facility has comprehensive manuals detailing operations, maintenance, instrumentation, and emergency procedures. All procedures are treated as active documents, with annual reviews.


OCWA has additional "Value Added" and operational support services that the Village of Merrickville-Wolford benefits from including:

- Access to a network of operational compliance and support experts at the regional and corporate level, as well as affiliated programs that include the following:
  - Quality & Environmental Management System, Occupational Health & Safety System and an internal compliance audit system.
  - Process Data Collection (PDC) facility operating information repository, which consolidates field data, online instrumentation, and electronic receipt of lab test results for reporting, tracking and analysis.
  - Work Management System (WMS) that tracks and reports maintenance activity, and creates predictive and preventative reports.
  - Outpost 5 wide-area SCADA system allows for process optimization and data logging, process trending, remote alarming and optimization of staff time.
- Client reporting which includes operational data, equipment inventory, financial statements, maintenance work orders, and capital status reports
- Site-Specific Contingency Plans and Standard Operating Procedures
- Use of accredited laboratories
- Additional support in response to unusual circumstances, and extra support in an emergency.
- Use of sampling schedules for external laboratory sampling


## Treatment Flows

### Raw Flow (m<sup>3</sup>/d)

Annual average flow for 2021 was 475.4 m<sup>3</sup>/d. The Average daily flow rated capacity is 800 m<sup>3</sup>/d. This is based on an annual average. A flow reduction plan was established for 2018.



### Annual Comparison (m<sup>3</sup>)



## Septage Volumes

Month	Septage Received (m <sup>3</sup> )
March	9.6
April	16.3
May	14.0
June	17.7
July	19.6
August	14.8
September	13.2
October	14.8

## Raw Sewage Quality

Results of raw sewage concentrations and loadings are available in the Facility Performance Assessment Report in Appendix A.

## Effluent Quality

The limits are based on current requirements in the facilities Environmental Compliance Approval. Laboratory samples are submitted to an accredited laboratory for regulatory analysis.

The Federal Government also regulates certain sewage effluent parameter under the Federal Fisheries Act. The results are submitted to Environment Canada (WESR) on a quarterly basis.

### Effluent Exceedance Summary Limit

Sample	Date	Parameter	Exceedance of	Limit	Value
Final Effluent	February 2021	Phosphorus	Regulatory Limit	0.63 mg/L	0.68 mg/L


### Other Issues

There were no other issues during the reporting year.


**Effluent Parameter Summary**

**Carbonaceous Biological Oxygen Demand (CBOD5)**

Concentration (mg/L)




Loading (kg/d)




**Total Suspended Solids**

Concentration (mg/L)




Loading (kg/d)






**Total Phosphorus**

Concentration (mg/L)




Loading (kg/d)



**Total Ammonia Nitrogen**

Limit is based on effluent being “Non-Acutely Lethal”. See Acute Lethality results below.

Concentration (mg/L)




**Acute Lethality**

Semi-Annual sampling is required for acute lethality (Rainbow Trout and Daphnia Magna). Results are displayed as % mortality.


Date	Rainbow Trout	Daphnia Magna
April 20-2021	0%	0%
September 15, 2021	0%	0%

**E-coli**

**SBR1**




**SBR2**




**pH**

**SBR 1**



**SBR 2**



## Biosolids

Sludge generated from the treatment plant was spread on agricultural land during the spreading season as per the Nutrient Management Act O.Reg 267/03. During the winter sludge is stored on-site until the Organic Soil Conditioning Sites are available for spreading.


During the spreading season the operating authority contracts sludge haulage. Sludge haulage is contracted to Terrapure Environmental who maintains a bank of available sites for disposal of biosolids. Biosolids quality report in Appendix B.

### Biosolids Disposal Summary

For 2021, Terrapure hauled 800 m<sup>3</sup> from the sludge holding tank.

Date	Site	NASM Plan number	Volume (m <sup>3</sup> )
May 7-18 2021	Sunol Farms – Turner Farm	24589	800
			800

### Annual Comparison



Note: In 2018, extremely wet weather conditions resulted in limited hauling opportunities.

## Summary of Complaints

The following were received community complaints related to the operations of the Merrickville WPCP and Collection System.

Date	Location	Details	Corrective Action Taken
There were no Community Complaints during the reporting period.			

## Summary of Bypass/Overflows

Date	Location	Details	Corrective Action Taken
There were no Bypass' or Overflows during the reporting period.			

## Summary of Spills/Abnormal Discharges

Date	Location	Details	Corrective Action Taken
March 12 2021	St. Lawrence Street	Blocked sanitary sewer	The spill was disinfected using chlorine upstream of the storm sewer and dechlorination was used before it entered the storm sewer

## Maintenance

OCWA uses a risk-based preventative maintenance framework that ensures assets are maintained to manufacturer's and/or industry standards. Maintenance is completed using various tools and operational supports. The Eastern Regional Hub has specialized certified staff such as Millwrights, Electricians and Instrumentation Specialists to name a few.

OCWA uses a Workplace Maintenance System (WMS). WMS is a maintenance tracking system that can generate work orders as well as give summaries of completed and scheduled work. During the year, the operating authority at the facility generates scheduled work orders on a weekly, monthly and annual basis. The service work is recorded in the work order history. This ensures routine and preventive maintenance is carried out. Emergency and capital repair maintenance is completed and added to the system.

Capital projects are listed and provided to the Village of Merrickville-Wolford in the form of a "Capital Forecast". This list is developed by facility staff and provides recommendations for facility components requiring upgrading or improvement.

### Maintenance Highlights

WO #	Summary
2094235	Capital Raw sewage pump repair
2094244	Capital collection system flushing and camera
2094252	Capital Replacement UV bulbs bank A
2094254	Capital Tools replacement
2094258	Capital Jersey barrier parking lot

WO #	Summary
2094259	Capital Service Entrance fence and gate
2090874	Capital reroute wire for septage pumps
2091337	Capital UV bank B led light failure
2092866	Capital Electrical Outlets
2092873	Capital Electrical work for pressure washer
2131836	Capital Disconnect plug chemical pump
2132146	Capital Install trip guard septage tank
2360581	Capital TSSA Inspection Fuel Tanks X3
2361991	Capital Surge protector module generator building
2405079	Capital UV parts repair
2452175	Capital Abs blower #2 repairs
2503240	Capital UPS replacement
2177182	Capital Emergency sewage blockage
2177344	Capital Infiltration control supplies and labor
2223393	Capital Surge protectors for STP and SPS
2225055	Capital Combo vac truck work
2225781	Capital Gas Heaters and Backflow preventers
2225785	Capital SCADA/plc communication failure
2266257	Capital Generator Frost plug leak
2268652	Capital Flowmeter Annual Calibration
2361762	Capital Lifting equipment repairs
2361989	Capital Digester pump failure / electrical work
2363128	Capital Chemical tank repair
2407190	Capital Blower cooling fan replacement motor
2453048	Capital Repair faulty UV boards
2503717	Capital Security camera and lights

### Calibration

The flow meters were calibrated on May 19, 2021. Calibration Reports are attached in Appendix C. There is no on-line effluent monitoring equipment installed at this facility.

# Appendix A

---

## Facility Performance Assessment Report

Ontario Clean Water Agency  
Performance Assessment Report Wastewater/Lagoon  
From: 01/01/2021 to 31/12/2021

Facility: [1162] MERRICKVILLE WASTEWATER TREATMENT FACILITY  
Works: [110001729]

	01/2021	02/2021	03/2021	04/2021	05/2021	06/2021	07/2021	08/2021	09/2021	10/2021	11/2021	12/2021	<-Total-->	<-Avg-->	<-Max-->	<-Criteria-->
<b>Flows:</b>																
Raw Flow: Total - Raw Sewage (m³)	15261.00	8773.00	24531.00	20142.00	19671.00	10791.00	9961.00	8976.00	8980.00	11730.00	15195.00	19519.00	173530.00			
Raw Flow: Avg - Raw Sewage (m³/d)	492.29	313.32	791.32	671.40	634.55	359.70	321.32	289.55	299.33	378.39	506.50	629.65		473.94		
Raw Flow: Max - Raw Sewage (m³/d)	790.00	404.00	1676.00	1095.00	981.00	418.00	411.00	344.00	392.00	726.00	673.00	1120.00			1676.00	
Eff. Flow: Total - Final Effluent (m³)	14964.00	8788.00	24244.00	19748.00	19210.00	11543.00	11540.00	9525.00	8922.00	12924.00	14865.00	19342.00	175615.00			
Eff. Flow: Avg - Final Effluent (m³/d)	482.71	313.86	782.06	658.27	619.68	384.77	372.26	307.26	297.40	416.90	495.50	623.94		479.55		
Eff. Flow: Max - Final Effluent (m³/d)	799.00	403.00	1665.00	1064.00	981.00	507.00	501.00	411.00	408.00	707.00	675.00	1103.00			1665.00	
<b>Carbonaceous Biochemical Oxygen Demand: CBOD:</b>																
Eff: Avg cBOD5 - Final Effluent (mg/L)	< 3.000	< 3.000	< 3.000	< 3.000	< 3.000	< 3.000	< 3.750	< 3.000	< 3.000	< 3.000	< 3.000	< 3.000		< 3.063	< 3.750	15.0
Eff: # of samples of cBOD5 - Final Effluent (mg/L)	4	4	6	4	5	4	4	5	4	4	5	4	53			
Loading: cBOD5 - Final Effluent (kg/d)	< 1.448	< 0.942	< 2.346	< 1.975	< 1.859	< 1.154	< 1.396	< 0.922	< 0.892	< 1.251	< 1.487	< 1.872		< 1.462	< 2.346	
<b>Biochemical Oxygen Demand: BOD5:</b>																
Raw: Avg BOD5 - Raw Sewage (mg/L)	96.000	223.000	159.000	80.000	71.000	134.000	235.000	216.000	213.000	152.000	97.000	112.000		149.000	235.000	
Raw: # of samples of BOD5 - Raw Sewage (mg/L)	1	1	1	1	1	1	1	1	1	1	1	1	12			
<b>Total Suspended Solids: TSS:</b>																
Raw: Avg TSS - Raw Sewage (mg/L)	150.000	330.000	310.000	124.000	86.000	176.000	236.000	255.000	255.000	220.000	120.000	162.000		202.000	330.000	
Raw: # of samples of TSS - Raw Sewage (mg/L)	1	1	1	1	1	1	1	1	1	1	1	1	12			
Eff: Avg TSS - Final Effluent (mg/L)	< 3.250	< 3.500	< 4.500	< 3.500	< 3.600	< 5.250	< 5.250	< 6.200	< 6.500	< 5.250	< 6.600	< 6.000		< 4.950	< 6.600	15.0
Eff: # of samples of TSS - Final Effluent (mg/L)	4	4	6	4	5	4	4	5	4	4	5	4	53			
Loading: TSS - Final Effluent (kg/d)	< 1.569	< 1.099	< 3.519	< 2.304	< 2.231	< 2.020	< 1.954	< 1.905	< 1.933	< 2.189	< 3.270	< 3.744		< 2.311	< 3.744	
Percent Removal: TSS - Raw Sewage (mg/L)	97.833	98.939	98.548	97.177	95.814	97.017	97.775	97.569	97.451	97.614	94.500	96.296			98.939	
<b>Total Phosphorus: TP:</b>																
Raw: Avg TP - Raw Sewage (mg/L)	3.200	7.560	6.530	2.490	1.980	4.420	6.720	5.790	5.640	6.360	3.050	3.260		4.750	7.560	
Raw: # of samples of TP - Raw Sewage (mg/L)	1	1	1	1	1	1	1	1	1	1	1	1	12			
Eff: Avg TP - Final Effluent (mg/L)	0.123	0.675	0.180	0.135	< 0.380	0.148	0.190	0.460	0.362	0.138	0.095	0.095		< 0.254	0.675	0.63
Eff: # of samples of TP - Final Effluent (mg/L)	4	4	6	4	5	4	4	5	4	4	5	4	53			
Loading: TP - Final Effluent (kg/d)	0.059	0.212	0.141	0.089	< 0.235	0.057	0.071	0.141	0.108	0.066	0.059	0.059		< 0.109	0.235	
Percent Removal: TP - Raw Sewage (mg/L)	96.172	91.071	97.243	94.578	80.808	96.663	97.173	92.055	93.573	97.524	95.475	97.086			97.524	
<b>Nitrogen Series:</b>																
Raw: Avg TKN - Raw Sewage (mg/L)	24.600	51.600	44.600	17.800	13.500	30.500	51.500	45.300	42.000	56.600	24.000	21.900		35.325	56.600	
Raw: # of samples of TKN - Raw Sewage (mg/L)	1	1	1	1	1	1	1	1	1	1	1	1	12			
Eff: Avg TAN - Final Effluent (mg/L)	< 0.023	0.050	< 1.287	0.020	0.024	0.020	0.035	< 0.093	0.083	0.065	< 0.020	< 0.023		< 0.145	1.287	
Eff: # of samples of TAN - Final Effluent (mg/L)	4	4	6	4	5	4	4	4	4	4	5	4	52			
Loading: TAN - Final Effluent (kg/d)	< 0.011	0.016	< 1.006	0.013	0.015	0.008	0.013	< 0.028	0.025	0.027	< 0.010	< 0.014		< 0.099	1.006	
<b>Disinfection:</b>																
Eff: GMD E. Coli - Eff SBR2 (cfu/100mL)	1.000	22.539	25.391	1.442	2.031	10.000	8.000	1.000	50.000	1.000	1.000	3.606		10.584	50.000	
Eff: GMD E. Coli - Eff SBR1 (cfu/100mL)	3.684	1.000	2.000	1.000	1.442	6.000	24.083	2.000	1.000	1.817	2.893	5.292		4.351	24.083	
Eff: # of samples of E. Coli - Eff SBR2 (cfu/100mL)	2	2	6	3	4	1	1	2	1	1	1	2	26			
Eff: # of samples of E. Coli - Eff SBR1 (cfu/100mL)	3	2	3	3	3	1	2	1	2	3	4	2	29			



# Appendix B

---

## Biosolids Quality Report

Ontario Clean Water Agency  
 Biosolids Quality Report - Liquid  
 Digester Type: AEROBIC  
**Solids and Nutrients**

Facility: MERRICKVILLE WASTEWATER TREATMENT FACILITY  
 Works: 1162  
 Period: 01/01/2021 to 12/01/2021

Facility Works Number: 1.10001729E8  
 Facility Name: MERRICKVILLE WASTEWATER TREATMENT FACILITY  
 Facility Owner: Municipality: The Village of Merrickville-Wolford  
 Facility Classification: Class 2 Wastewater Treatment  
 Receiver: Rideau River  
 Service Population:  
 Total Design Capacity: m3/day  
 Period Being Reported: 01/01/2021 12/01/2021

Note: all parameters in this report will be derived from the Bslq Station

Month	Total Sludge Hauled (m3)	Avg. Total Solids (mg/L)	Avg. Volatile Solids (mg/L)	Avg. Total Phosphorus (mg/L)	Ammonia (mg/L)	Nitrate (mg/L)	Nitrite (mg/L)	TKN (mg/L)	Ammonia + Nitrate (mg/L)	Potassium (mg/L)
<b>Site</b>	<b>MERRICKVILLE WASTEWATER TREATMENT FACILITY</b>									
<b>Station</b>	<b>Bslq Station only</b>									
<b>Parameter Short Name</b>	<b>HauledVol</b>	<b>TS</b>	<b>VS</b>	<b>TP</b>	<b>NH3p_NH4p_N</b>	<b>NO3-N</b>	<b>NO2-N</b>	<b>TKN</b>	<b>calculation in report - no T/S</b>	<b>K</b>
<b>T/s</b>	<b>IH Month.Total</b>	<b>Lab Published Month Mean</b>	<b>Lab Published Month Mean</b>	<b>Lab Published Month Mean</b>	<b>Lab Published Month Mean</b>	<b>Lab Published Month Mean</b>	<b>Lab Published Month Mean</b>	<b>Lab Published Month Mean</b>		<b>Lab Published Month Mean</b>
<b>Jan</b>		54,600.000	35,400.000	1,360.000	431.000	1.000	1.000	2,540.000	216.000	41.700
<b>Feb</b>		60,400.000	37,600.000	1,020.000	272.000	0.100	0.100	1,880.000	136.050	41.400
<b>Mar</b>		56,300.000	35,200.000	2,330.000	259.000	0.100	0.100	4,350.000	129.550	41.600
<b>Apr</b>		62,800.000	39,200.000	1,160.000	262.000	1.000	1.000	2,100.000	131.500	54.000
<b>May</b>	801.000	41,950.000	24,900.000	982.500	319.000	1.200	0.550	1,965.000	160.100	36.100
<b>Jun</b>										
<b>Jul</b>										
<b>Aug</b>		34,700.000	25,000.000	784.000	196.000	1.000	1.000	1,560.000	98.500	38.200
<b>Sep</b>		46,300.000	26,600.000	1,130.000	333.000	1.000	1.000	1,800.000	167.000	40.500





Ontario Clean Water Agency  
 Biosolids Quality Report - Liquid - Based on Last 4 Samples  
 Digester Type: AEROBIC

Facility: MERRICKVILLE WASTEWATER TREATMENT FACILITY  
 Works: 1162  
 Period: 01/01/2021 to 12/01/2021

Note: all parameters in this report will be derived from the Bslq Station

Parameter Short Name	Time Series	08/16/2021	09/20/2021	10/18/2021	12/06/2021	Average	Metal Concentrations in Sludge (mg/kg):	Max. Permissible Metal Concentrations (mg/kg of Solids):
As (mg/L)	Lab Published	0.100	0.100	0.200	0.100	0.125	2.747	170
Cd (mg/L)	Lab Published	0.060	0.050	0.150	0.090	0.088	1.934	34
Co (mg/L)	Lab Published	0.160	0.260	0.250	0.440	0.277	6.088	340
Cr (mg/L)	Lab Published	0.790	1.130	1.320	1.270	1.128	24.791	2800
Cu (mg/L)	Lab Published	21.600	34.100	41.400	39.300	34.100	749.451	1700
Hg (mg/L)	Lab Published	0.016	0.023	0.021	0.025	0.021	0.462	11
Mo (mg/L)	Lab Published	0.400	0.640	0.810	0.790	0.660	14.505	94
Ni (mg/L)	Lab Published	0.810	1.360	2.340	2.000	1.627	35.758	420
Pb (mg/L)	Lab Published	0.900	1.400	1.700	1.500	1.375	30.220	1100
Se (mg/L)	Lab Published	0.200	0.300	0.300	0.100	0.225	4.945	34
Zn (mg/L)	Lab Published	33.400	51.900	63.800	65.500	53.650	1,179.121	4200
E. Coli: Dry Wt (cfu/g)	Lab Published						E.Coli average is the GMD	
TS (mg/L)	Lab Published	34,700.000	46,300.000	49,500.000	51,500.000	45,500.000		
VS (mg/L)	Lab Published	25,000.000	26,600.000	29,700.000	31,900.000	28,300.000		
TP (mg/L)	Lab Published	784.000	1,130.000	770.000	1,110.000	948.500		
NO2-N (mg/L)	Lab Published	1.000	1.000	1.000	0.100	0.775		
TKN (mg/L)	Lab Published	1,560.000	1,800.000	1,140.000	1,880.000	1,595.000		
K (mg/L)	Lab Published	38.200	40.500	42.700	46.000	41.850		
NH3p_NH4p_N (mg/L)	Lab Published	196.000	333.000	269.000	202.000	250.000		
NO3-N (mg/L)	Lab Published	1.000	1.000	1.000	0.100	0.775		

# Appendix C

---

## Flow Meter Calibration Records

# CapitalControls

Electrical/Control Panels – PLC/SCADA Programming – Instrumentation Calibrations

10-830 Industrial Ottawa, ON K1G-4B8 Ph. 613 248-1999 Fax: 613 248-1997

## **Town of Merrickville**

### **Calibration of Waste Water Flow Meters**

**Report May 19 2021**

Prepared For: O.C.W.A. Merrickville

Calibration Date: May 19<sup>th</sup> 2021

Calibration Due: May 19<sup>th</sup> 2022

Verifications performed by: Tim Stewart

Report prepared by: Tim Stewart

# CapitalControls

Electrical/Control Panels – PLC/SCADA Programming – Instrumentation Calibrations

10-830 Industrial Ottawa, ON K1G-4B8 Ph. 613 248-1999 Fax: 613 248-1997

## Table of Contents

<b>1</b>	<b>LIST OF VERIFIED DEVICES</b>	<b>- 2 -</b>
<b>2</b>	<b>EQUIPMENT USED</b>	<b>- 2 -</b>
<b>3</b>	<b>PROCEDURES USED</b>	<b>- 2 -</b>
<b>3.1</b>	<b>Flowmeter Verification</b>	<b>- 2 -</b>
<b>4</b>	<b>INSTRUMENT VERIFICATION</b>	<b>- 3 -</b>
<b>4.1</b>	<b>FIT 701 Sludge Flow</b>	<b>- 4 -</b>
<b>4.2</b>	<b>FIT 402 Final Effluent Flow</b>	<b>- 5 -</b>
<b>4.3</b>	<b>FIT 501 Septage/Supernatant Flow</b>	<b>- 6 -</b>
<b>4.4</b>	<b>FIT 305 Raw Sewage Flow</b>	<b>- 7 -</b>
<b>5.1</b>	<b>Calibration Certificates</b>	<b>- 8 -</b>



## 1 List of Verified Devices

This letter is to confirm that annual verification on the following devices has been completed.

ID	Process	Make/Model	Results
FIT-701	Sludge	E and H / Promag 53 W	Passed
FIT-402	Final Effluent	E and H / Promag 53 W	Passed
FIT-501	Septage/Supernatant	E and H / Promag 53 W	Passed
FIT-305	Raw Sewage	E and H / Promag 53 W	Passed

## 2 Equipment Used

The following equipment was used to perform the calibrations:

E and H Fieldcheck

## 3 Procedures Used

To verify the equipment standard verification procedures developed by the Township were used and standard industry practice.

### 3.1 Flowmeter Verification

*Verification, Magnetic Flow Meter:*

The verification of Endress & Hauser Flow measuring devices (the device under test) are checked for the following characteristic values:

1. Functionality and deviation in flow measurement.

10-830 Industrial Ave. Ottawa, ON K1G-4B8 Ph. 613 248-1999 Fax: 613 248-1997

2. Deviation in the current and frequency outputs in reference to the flow rate data determined by the measuring device.

**Measuring devices:** The verification system consists of the FlowCheck flow simulator, the Simubox and the appropriate connection cables.

**FieldCheck:** The FieldCheck flow simulator generates the flow simulation signals and processes the measured values sent back from the transmitter.

**Simubox:** The Simubox ensures that the FieldCheck simulation signal are correctly converted in the transmitter, by comparing the measurements returned from the transmitter to data stored within the Simubox for various parameters (Electromagnetic Field vs. Flow, Flow vs. Current, and various other parameters important in verifying the proper functionality of the device under test.

## 4 Instrument Verification

See the following pages of reports for individual equipment.

## 4.1 FIT 701 Sludge Flow

Flow Transmitter  
As Found Results

Instrument Calibration/Verification Report

Date: May 19 , 2021

### Client Details

Customer O.C.W.A. Merrickville  
Contact Jeff Morrison  
613-257-9223

Calibrations by: Tim Stewart  
Capital Controls  
613-248-1999

### Instrument Details

Manufacturer Eand H  
Model Promag 53 DN 100  
Serial Number KF081F16000  
Location W.W.T.P.  
Process Sludge  
Tag ID FIT-701  
Output 4-20 mA

### Calibration Equipment

Make	Fluke Meter	FieldCheck
Model	725	50098801
Serial #	8759025	99081402000

Errors are expressed in percentage of Full Scale

### Test Procedure

FieldCheck

#### Zero Test

Current out = +0.001 mA

#### Amplifier

MP1 = -0.45 %  
MP2 = -0.48 %  
MP3 = +0.03 %  
MP4 = +0.07 %

#### Current Output

MP1 = +0.002 mA  
MP2 = -0.009 mA  
MP3 = +0.003 mA  
MP4 = +0.002 mA

#### Sensor Test

Coil Current Rise = 6.40  
Rated for 5.00  
Potential Difference = 0.00

### Comments

The instrument under test has passed the annual calibration.

## 4.2 FIT 402 Final Effluent Flow

Flow Transmitter  
As Found Results

Instrument Calibration/Verification Report

Date: May 19, 2021

---

**Client Details**

Customer O.C.W.A. Merrickville  
Contact Jeff Morrison  
613-257-9223

Calibrations by: Tim Stewart  
Capital Controls  
613-248-1999

**Instrument Details**

Manufacturer Eand H  
Model Promag 53W DN 250  
Serial Number DB098C16000  
Location W.W.T.P.  
Process Final Effluent  
Tag ID FIT-402  
Output 4-20 mA

---

**Calibration Equipment**

Make	Fluke Meter	FieldCheck
Model	725	50098801
Serial #	8759025	99081402000

Errors are expressed in percentage of Full Scale

---

**Test Procedure**

FieldCheck

**Zero Test**

Current out = +0.001 mA

**Amplifier**

MP1 = -0.53 %  
MP2 = -0.48 %  
MP3 = -0.01 %  
MP4 = +0.03 %

**Current Output**

MP1 = +0.002 mA  
MP2 = -0.011 mA  
MP3 = +0.003 mA  
MP4 = +0.002 mA

**Sensor Test**

Coil Current Rise = 20.25  
Rated for 14.60  
Potential Difference = 0.00

---

**Comments**

The instrument under test has passed the annual calibration.

## 4.3 FIT 501 Septage/Supernatant Flow

Flow Transmitter  
As Found Results

Instrument Calibration/Verification Report

Date: May 19 , 2021

**Client Details**

Customer O.C.W.A. Merrickville  
Contact Jeff Morrison  
613-257-9223

Calibrations by: Tim Stewart  
Capital Controls  
613-248-1999

**Instrument Details**

Manufacturer Eand H  
Model Promag 53W DN 150  
Serial Number DB09BA16000  
Location W.W.T.P.  
Process Septage/Supernatant  
Tag ID FIT-501  
Output 4-20 mA

**Calibration Equipment**

Make	Fluke Meter	FieldCheck
Model	725	50098801
Serial #	8759025	99081402000

Errors are expressed in percentage of Full Scale

**Test Procedure**

FieldCheck

**Zero Test**

Current out = +0.001 mA

**Amplifier**

MP1 = -0.57 %  
MP2 = -0.02 %  
MP3 = -0.02 %  
MP4 = +0.01 %

**Current Output**

MP1 = +0.002 mA  
MP2 = -0.015 mA  
MP3 = +0.003 mA  
MP4 = +0.000 mA

**Sensor Test**

Coil Current Rise = 17.19  
Rated for 9.60  
Potential Difference = 3.26

**Comments**

The instrument under test has passed the annual calibration.

## 4.4 FIT 305 Raw Sewage Flow

Flow Transmitter  
As Found Results

Instrument Calibration/Verification Report

Date: May 19 , 2021

**Client Details**

Customer O.C.W.A. Merrickville  
Contact Jeff Morrison  
613-257-9223  
  
Calibrations by: Tim Stewart  
Capital Controls  
613-248-1999

**Instrument Details**

Manufacturer Eand H  
Model Promag 53W DN 150  
Serial Number DB098B16000  
Location W.W.T.P.  
Process Raw Sewage  
Tag ID FIT-305  
Output 4-20 mA

**Calibration Equipment**

Make	Fluke Meter	FieldCheck
Model	725	50098801
Serial #	8759025	99081402000

Errors are expressed in percentage of Full Scale

**Test Procedure**

FieldCheck

**Zero Test**

Current out = +0.002 mA

**Amplifier**

MP1 = -0.51 %  
MP2 = -0.02 %  
MP3 = -0.03 %  
MP4 = +0.02 %

**Current Output**

MP1 = +0.001 mA  
MP2 = -0.011 mA  
MP3 = -0.002 mA  
MP4 = -0.010 mA

**Sensor Test**

Coil Current Rise = 13.35  
Rated for 9.60  
Potential Difference = 3.29

**Comments**

The instrument under test has passed the annual calibration.

## 5.1 Calibration Certificates

### Calibration Certificate Kalibrations-Zertifikat

#### FieldCheck

Page 1 of 2  
Seite 1 of 2

Production Number Fabrikationsnummer	240223
Serial Number Seriennummer	990B1402000
Manufacturer Hersteller	Endress+Hauser Flowtec AG CH-4153 Reinach
Date Of Calibration Kalibrierdatum	03/03/2021
Location Ort	DG-Granwood
Testing Instruction Prüfungsweisung	CalCenter_2
Test Program Prüfprogramm	V1.01.10
Test Engineer Prüfer	Jamie
Used Test/Calibration Interface Verwendete Prüf-/Kalibriermittel	..
Used Test/Calibration Tools Verwendete Prüf-/Kalibriermittel	KalHley DMM2700 due 07/2021 Yokogawa CAL100 due 07/2021
Max. Deviation (Specification) Max. Abweichung (Spezifikation)	
Current Source Stromquelle	0,01% of end value / des Endwertes (20mA) + 0,02% of signal / des Signals
Frequency Source Frequenzgeber	0,01% of signal / des Signals
Notes Bemerkungen	The above mentioned calibration tools are traceable to national standards / NIST  Die oben genannten Kalibriermittel sind rückführbar auf nationale Normale

Date, Signature: 03/03/2021,



## Calibration Certificate Kalibrations-Zertifikat

### FieldCheck

Production Number / Fabrikationsnummer: 240223  
Serial Number / Seriennummer: 92061402000

Page 2 of 2  
Seite 2 of 2

Measuring Data On Incoming Inspection Messdaten bei der Eingangsprüfung		Rated Value Vorgabewert	Mess. Value Messwert	Limit Value +/- Grenzwert +/-	Pass / Fail Gut/Fehlerhaft
Current Input Strom-Eingang	mA	0.000	<b>0.000</b>	0.005	Pass/Gut
	mA	20.000	<b>20.003</b>	0.010	Pass/Gut
Frequency Input Frequenz-Eingang	Hz	0.0	<b>0.0</b>	0.0	Pass/Gut
	Hz	8000.0	<b>7999.9</b>	4.0	Pass/Gut

Measuring Data After Calibration Messdaten nach Kalibrierung		Rated Value Vorgabewert	Mess. Value Messwert	Limit Value +/- Grenzwert +/-
Current Input Strom-Eingang	mA	0.000	<b>0.002</b>	0.002
	mA	10.000	<b>10.003</b>	0.004
	mA	20.000	<b>20.001</b>	0.005
Frequency Input Frequenz-Eingang	Hz	0.0	<b>0.0</b>	0.0
	Hz	1000.0	<b>1000.0</b>	1.0
	Hz	8000.0	<b>8000.0</b>	2.0

### Functional Safety Check Funktionaler Sicherheitscheck

This unit has passed the complete Functional Safety Check.  
Alle voltages and currents produced by this unit are within tolerances.

Dieses Gerät hat den vollständigen funktionalen Sicherheitscheck bestanden.  
Alle von diesem Gerät produzierten Spannungen und Ströme sind innerhalb der Toleranz.

Date, Signature: 03/03/2021,





## Calibration Certificate Kalibrations-Zertifikat

### Simubox MID

Page 1 of 2  
Seite 1 of 2

Production Number Fabrikationsnummer	9784351
Serial Number Seriennummer	JA0FE402000
Manufacturer Hersteller	Endress+Hauser Flowtec AG CH-4153 Reinach

Date Of Calibration Kalibrierdatum	03/03/2021
Location Ort	DG-Greenwood
Testing Instruction Prüfanweisung	CalCenter_2
Test Program Prüfprogramm	V1.01.10
Test Engineer Prüfer	Jamie

Used Test-Calibration Interface Verwendete Prüf-Kalibrierachrichtstelle	-
Used Test-Calibration Tools Verwendete Prüf-Kalibriermittel	Kalithley DMM2700 due 07/2021 Yokogawa CAL100 due 07/2021
Max. Deviation (Specification) Max. Abweichung (Spezifikation)	
Current Source Stromquelle	0,01% of end value / des Endwertes (20mA) + 0,02% of signal / des Signals
Frequency Source Frequenzgeber	0,01% of signal / des Signals

Notes Bemerkungen	The above mentioned calibration tools are traceable to national standards / NIST  Die oben genannten Kalibriermittel sind rückführbar auf nationale Normale
----------------------	---

Date, Signature: 03/03/2021,



## Calibration Certificate Kalibrations-Zertifikat

### SimuBox MID

Production Number / Fabrikationsnummer:  
Serial Number / Seriennummer:

8784051  
LA01=402000

Page 2 of 2  
Seite 2 of 2

Measuring Data On Incoming Inspection Messdaten bei der Eingangsprüfung (Calculated Mean Values / Berechnete Mittelwerte)	Rated Value Vorgabewert [µV]	Meas. Value Messwert [µV]	Lim: Value +/- Grenzwert +/- [µV]	Pass / Fail Gut/Fehlerraff
Meas. Range 1	57.0	57.0	1.0	Pass/Gut
Meas. Range 2	331.0	332.7	3.0	Pass/Gut
Meas. Range 3	2084.0	2081.7	10.0	Pass/Gut
Meas. Range 4	11826.0	11821.2	20.0	Pass/Gut

Measuring Data After Calibration Messdaten nach Kalibrierung (Calculated Mean Values / Berechnete Mittelwerte)	Rated Value Vorgabewert [µV]	Meas. Value Messwert [µV]	Lim: Value +/- Grenzwert +/- [µV]
Meas. Range 1	50.0	49.8	0.5
Meas. Range 2	300.0	300.0	1.0
Meas. Range 3	2000.0	2000.0	3.0
Meas. Range 4	10000.0	9999.6	5.0

Date, Signature: 03/09/2021,

